


## Bohrabstände



Type	H	L	A	A1	B
VEI 300/1 MW	592	592	440	-	440
VEI 500/1 MW	592	892	740	-	440
VEI 700/1 MW	592	1192	1040	-	440
VEI 800/1 MW	592	1492	1340	670	440
VEI 1000/1 MW	750	1500	1340	670	600

## Auslegung

	Passivhaus	Niedrig- energiehaus	Altbau	Zusatz- heizung	ungedämmter Wintergarten
erforderliche Leistung [ $\text{W}/\text{m}^2$ ]	25	47	64	37	98
15 $\text{m}^2$	375	705	960	555	1470
25 $\text{m}^2$	625	1175	1600	925	2450